

**ADDENDUM NO. 3 TO
PROPOSAL CONTRACT
FOR THE CONSTRUCTION OF
CONTRACT 1
MAIN STREET TO MAIN STREET MULTIMODAL CONNECTOR PROJECT**

SEPTEMBER 16, 2013

This addendum forms a part of the Contract Documents and modifies the original specifications and drawings, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of 1 page and 0 attachments.

Item No. 1: DRAWINGS, SHEET E1:

A. Clarification – the “vendor outdoor rated cable” referred to in Key Note #5 shall run from the data injector located inside the NEMA 4 Enclosure to the first light fixture and from there shall daisy-chain from fixture to fixture. The cable shall be secured with two-hole straps at intervals not exceeding 36 inches.

B. Clarification – the “step-down transformer” referred to in Key Note 3# shall be rated 2kVA minimum.

ALLEN & HOSHALL
1661 INTERNATIONAL DRIVE, SUITE 100
MEMPHIS, TENNESSEE 38120
JOB NO. 71790