INSPECTION SURVEY			MEMPHIS FIRE DEPARTMENT FIRE PREVENTION BUREAU	OFFICE OF THE FIRE MARSHALL 2668 AVERY AVENUE MEMPHIS,TN 38112 PH: 636-5401
U & O	ROUTINE ✓	COMPLAINT		

LOCATION	ZIP	FIRM NAME	OCCUPANCY
2363 PARK AVE	38114	Juice Orange Mound	
OWNER: Britney Thorton		MANAGER	Statements are aids to memory only, not quotations of the City Codes. / Summons

A. FIRE EXTINGUISHERS

1. ☐ Provide a_____rated fire extinguisher for the _____area.
2. ☐ Provide a 40 B.C. rated fire extinguisher for the kitchen, mounted at least 10 feet from the vent-a-hood.
3. ☐ All out of service extinguishers are to be recharged or replaced. When an extinguisher is out of service for maintenance, it is to be replaced by an extinguisher of the same type and at least equal rating.
4. ☐ All extinguishers are to have annual maintenance and be inspected monthly with a record of the maintenance securely attached to the extinguisher.
5. ☐ Dry chemical and Halon extinquishers are to have 6 year maintenance and be hydrostatically tested at 12 year intervals.

B. EXITS, EXITWAYS AND EMERGENCY LIGHTING

1. ☐ Locked or obstructed exit doors are a violation of the Fire Code.
2. ☐ Locks for exit doors are to be readily distinguishable as locked.
3. ☐ The required width of every corridor shall be maintained.
4. ☐ Required aisles shall be maintained so as to provide access to exits.
5. ☐ Hold open devices and automatic door closures, where provided shall be maintained.
6. ☐ No fire door may be blocked open or otherwise made inoperable.
7. ☐ Stairs serving as required means of egress shall be clear of all obstructions.
8. ☐ Exit light not illuminated; repair or replace.
9. ☐ Exit light not visible from exit approach, provide direction sign to the exit.
10. ☐ Exits and exit stairways are to be illuminated at all times when the building is occupied.
11. ☐ All required exits shall be equipped with approved exit signs in occupancies of 50 or more.
12. ☐ Emergency generators shall be inspected weekly and shall be exercised under load at least every 30 days in accordance with NFPA 110. Provide emergency lighting where required.

C. FIRE PROTECTION SYSTEMS AND APPLIANCES

1. ☐ Provide an approved fire alarm system complying with NFPA 72
2. ☐ The manual fire alarm system is to be tested semiannually and a record of the tests kept on the premises.
3. ☐ Fire alarm system cut-off or inoperative; failure to notify the Fire Prevention Bureau of an inoperative system is a misdemeanor.
4. ☐ Smoke detectors shall be visually inspected at least semiannually and tested in accordance with NFPA 72 E annually.
5. ☐ Smoke detector inoperative; repair or replace.
6. ☐ All smoke detectors other than spot type are to have a sensitivity test every two years.
7. ☐ Central station personnel are to test all sprinkler alarm devices and tamper switches bimonthly.
8. ☐ Atrium smoke removal and control systems shall be tested semiannually.
9. ☐ All horizontal or vertical sliding and rolling fire doors are to be inspected and tested annually.
10. ☐ An approved smoke detector is to be provided within the dwelling unit in an apartment house, condominium, dormitory or duplex and every guest room in a motel and hotel. A detector is also required at the head of a stairway leading to an occupied area and the head of each interior basement stairway.
11. ☐ Records of all required inspections and tests of fire protection systems and devices shall be kept on the premises.
12. ☐ The standpipe system is to be tested at 5 year intervals and a certificate of inspection forwarded to the Fire Prevention Bureau.
13. ☐ The underground and exposed piping for sprinkler systems and hydrants shall be flow tested to determine the interior condition of the piping at least every 5 years.
14. ☐ The fire pump is to be started by a drop in pressure in the system every 7 days and a record is to be kept on the premises of the test.
15. ☐ Provide an automatic fire suppression system in accordance with the International Mechanical Code.
16. ☐ The automatic fire suppression system is to be tested semiannually and a certificate of inspection forwarded to the Fire Prevention Bureau.
17. ☐ Hydrants are to be visually inspected monthly and at least once a year they shall be opened and closed to ensure proper operation and shall be properly lubricated.
18. ☐ Provide all weather roadway access to fire hydrants.
19. ☐ All control valves to standpipe and sprinkler systems are to be visually inspected monthly.
20. ☐ Sprinkler system gauges shall be inspected monthly and are to be tested or replaced every 5 years.
21. ☐ The main drain, waterflow alarm devices, pressure switches, quick-opening devices and tamper switches are to be tested quarterly.
22. ☐ A complete inspection and test of the sprinkler system in accordance with NFPA 25 shall be conducted at least annually by a licensed sprinkler contractor.
23. ☐ The Fire Department connection is to be inspected monthly, if the caps are missing the interior of the connection shall be inspected for obstructions.
24. ☐ The hydraulic name plate is to be inspected quarterly.

D. GENERAL

1. ☐ Extension cords cannot be used as a substitute for fixed wiring; spliced cords are not permitted.
2. ☐ A minimum of 30 inches clearance shall be provided in front of electrical control panels for access.
3. ☐ Provide a street number that can be readily seen from the street.
4. ☐ All openings in a fire rated partition shall be sealed with approved noncombustible material to protect against passage of smoke and fire.
5. ☐ Hazardous accumulation of waste materials or debris must be removed from premises.
6. ☐ Signs stating the maximum occupant load shall be posted in a conspicuous place. Said capacity shall not be exceeded.
7. ☐ Fire drill conducted this date. Exited _____ persons. Drill was _____ Satisfactory _____ Unsatisfactory.
8. ☐ Spraying operation does not comply with the Standard Fire Code.
9. ☐ Storage of flammable and/or combustible liquids are to be stored in safety cans or approved cabinet or room.
10. ☐ Premises and equipment in good order, no visible hazards observed this date.

REMARKS

*As per Fire Marshal "You are allowed to operate this facility as long as you stay under nine people total. And you are in the process with the building Dept to get approved as a Homeless Shelter/warming Center".

* You shall still remain under Fire watch until this problem is resolved.

* You shall not operate this address as a ~~[illegible]~~ warming center ~~[illegible]~~ until cleared by the Building Dept and the Fire Marshals office.

The above items are to be corrected as soon as possible; a reinspection will be conducted _____ to verify compliance. Failure to correct the above deficiencies by the compliance date may result in a court summons being issued. Refusal to accept the summons may result in arrest. Any request to provide alternate protection must be filed with the Fire Code Board of Appeals within (15) days.

INSPECTOR	INSPECTION DATE	TIME IN	TIME OUT	1ST REINSP. DATE:	2ND REINSP. DATE:	3RD REINSP. DATE:
Brewer	1-3-21	0900				

COPY RECEIVED BY	POSITION	PHONE NO.	ITEM_____ REFERRED	DATE CORRECTED
[signature]	Executive Director	901 620-8295		

INSPECTION SURVEY			MEMPHIS FIRE DEPARTMENT FIRE PREVENTION BUREAU	OFFICE OF THE FIRE MARSHALL 2668 AVERY AVENUE MEMPHIS,TN 38112 PH: 636-5401
U & O	ROUTINE ✓	COMPLAINT		

LOCATION	ZIP	FIRM NAME	OCCUPANCY
2363 Park Ave		Juice Orange Mound	
OWNER		MANAGER	Statements are aids to memory only, not quotations of the City Codes. / Summons
Britney Thornton			

A. FIRE EXTINGUISHERS

1. ☐ Provide a_____rated fire extinguisher for the _____area.
2. ☐ Provide a 40 B.C. rated fire extinguisher for the kitchen, mounted at least 10 feet from the vent-a-hood.
3. ☐ All out of service extinguishers are to be recharged or replaced. When an extinguisher is out of service for maintenance, it is to be replaced by an extinguisher of the same type and at least equal rating.
4. ☐ All extinguishers are to have annual maintenance and be inspected monthly with a record of the maintenance securely attached to the extinguisher.
5. ☐ Dry chemical and Halon extinquishers are to have 6 year maintenance and be hydrostatically tested at 12 year intervals.

B. EXITS, EXITWAYS AND EMERGENCY LIGHTING

1. ☐ Locked or obstructed exit doors are a violation of the Fire Code.
2. ☐ Locks for exit doors are to be readily distinguishable as locked.
3. ☐ The required width of every corridor shall be maintained.
4. ☐ Required aisles shall be maintained so as to provide access to exits.
5. ☐ Hold open devices and automatic door closures, where provided shall be maintained.
6. ☐ No fire door may be blocked open or otherwise made inoperable.
7. ☐ Stairs serving as required means of egress shall be clear of all obstructions.
8. ☐ Exit light not illuminated; repair or replace.
9. ☐ Exit light not visible from exit approach, provide direction sign to the exit.
10. ☐ Exits and exit stairways are to be illuminated at all times when the building is occupied.
11. ☐ All required exits shall be equipped with approved exit signs in occupancies of 50 or more.
12. ☐ Emergency generators shall be inspected weekly and shall be exercised under load at least every 30 days in accordance with NFPA 110. Provide emergency lighting where required.

C. FIRE PROTECTION SYSTEMS AND APPLIANCES

1. ☐ Provide an approved fire alarm system complying with NFPA 72
2. ☐ The manual fire alarm system is to be tested semiannually and a record of the tests kept on the premises.
3. ☐ Fire alarm system cut-off or inoperative; failure to notify the Fire Prevention Bureau of an inoperative system is a misdemeanor.
4. ☐ Smoke detectors shall be visually inspected at least semiannually and tested in accordance with NFPA 72 E annually.
5. ☐ Smoke detector inoperative; repair or replace.
6. ☐ All smoke detectors other than spot type are to have a sensitivity test every two years.
7. ☐ Central station personnel are to test all sprinkler alarm devices and tamper switches bimonthly.
8. ☐ Atrium smoke removal and control systems shall be tested semiannually.
9. ☐ All horizontal or vertical sliding and rolling fire doors are to be inspected and tested annually.
10. ☐ An approved smoke detector is to be provided within the dwelling unit in an apartment house, condominium, dormitory or duplex and every guest room in a motel and hotel. A detector is also required at the head of a stairway leading to an occupied area and the head of each interior basement stairway.
11. ☐ Records of all required inspections and tests of fire protection systems and devices shall be kept on the premises.
12. ☐ The standpipe system is to be tested at 5 year intervals and a certificate of inspection forwarded to the Fire Prevention Bureau.
13. ☐ The underground and exposed piping for sprinkler systems and hydrants shall be flow tested to determine the interior condition of the piping at least every 5 years.
14. ☐ The fire pump is to be started by a drop in pressure in the system every 7 days and a record is to be kept on the premises of the test.
15. ☐ Provide an automatic fire suppression system in accordance with the International Mechanical Code.
16. ☐ The automatic fire suppression system is to be tested semiannually and a certificate of inspection forwarded to the Fire Prevention Bureau.
17. ☐ Hydrants are to be visually inspected monthly and at least once a year they shall be opened and closed to ensure proper operation and shall be properly lubricated.
18. ☐ Provide all weather roadway access to fire hydrants.
19. ☐ All control valves to standpipe and sprinkler systems are to be visually inspected monthly.
20. ☐ Sprinkler system gauges shall be inspected monthly and are to be tested or replaced every 5 years.
21. ☐ The main drain, waterflow alarm devices, pressure switches, quick-opening devices and tamper switches are to be tested quarterly.
22. ☐ A complete inspection and test of the sprinkler system in accordance with NFPA 25 shall be conducted at least annually by a licensed sprinkler contractor.
23. ☐ The Fire Department connection is to be inspected monthly, if the caps are missing the interior of the connection shall be inspected for obstructions.
24. ☐ The hydraulic name plate is to be inspected quarterly.

D. GENERAL

1. ☐ Extension cords cannot be used as a substitute for fixed wiring; spliced cords are not permitted.
2. ☐ A minimum of 30 inches clearance shall be provided in front of electrical control panels for access.
3. ☐ Provide a street number that can be readily seen from the street.
4. ☐ All openings in a fire rated partition shall be sealed with approved noncombustible material to protect against passage of smoke and fire.
5. ☐ Hazardous accumulation of waste materials or debris must be removed from premises.
6. ☐ Signs stating the maximum occupant load shall be posted in a conspicuous place. Said capacity shall not be exceeded.
7. ☐ Fire drill conducted this date. Exited _____ persons. Drill was _____ Satisfactory _____ Unsatisfactory.
8. ☐ Spraying operation does not comply with the Standard Fire Code.
9. ☐ Storage of flammable and/or combustible liquids are to be stored in safety cans or approved cabinet or room.
10. ☐ Premises and equipment in good order, no visible hazards observed this date.

REMARKS #

*Owner Shall start a fire watch and Keep Record Owner Has been given directions on fire watch

*Owner Shall start V&O process with the buildings Dept.

* If Owner Continues Occupancy, Owner Shall Bring building up to R occupancy code According to what the building Dept Classifies you as.

* Build will be Required to be Sprinkled if it stays an R occupancy.

The above items are to be corrected as soon as possible; a reinspection will be conducted _____ to verify compliance. Failure to correct the above deficiencies by the compliance date may result in a court summons being issued. Refusal to accept the summons may result in arrest. Any request to provide alternate protection must be filed with the Fire Code Board of Appeals within (15) days.

INSPECTOR	INSPECTION DATE	TIME IN	TIME OUT	1ST REINSP. DATE:	2ND REINSP. DATE:	3RD REINSP. DATE:
Brewer	9-1-21	1100				

COPY RECEIVED BY	POSITION	PHONE NO.	ITEM_____ REFERRED	DATE CORRECTED
[signature]	Executive Director	901-620-8293		

INSPECTION SURVEY			MEMPHIS FIRE DEPARTMENT FIRE PREVENTION BUREAU	OFFICE OF THE FIRE MARSHALL 2668 AVERY AVENUE MEMPHIS,TN 38112 PH: 636-5401
U & O	ROUTINE	COMPLAINT		
	✓			

LOCATION	ZIP	FIRM NAME	OCCUPANCY	
2363 Park Ave	38114			
OWNER		MANAGER	Statements are aids to memory only, not quotations of the City Codes.	Summons

A. FIRE EXTINGUISHERS

1. ☐ Provide a_____rated fire extinguisher for the _____area.
2. ☐ Provide a 40 B.C. rated fire extinguisher for the kitchen, mounted at least 10 feet from the vent-a-hood.
3. ☐ All out of service extinguishers are to be recharged or replaced. When an extinguisher is out of service for maintenance, it is to be replaced by an extinguisher of the same type and at least equal rating.
4. ☒ All extinguishers are to have annual maintenance and be inspected monthly with a record of the maintenance securely attached to the extinguisher.
5. ☐ Dry chemical and Halon extinquishers are to have 6 year maintenance and be hydrostatically tested at 12 year intervals.

B. EXITS, EXITWAYS AND EMERGENCY LIGHTING

1. ☐ Locked or obstructed exit doors are a violation of the Fire Code.
2. ☐ Locks for exit doors are to be readily distinguishable as locked.
3. ☐ The required width of every corridor shall be maintained.
4. ☐ Required aisles shall be maintained so as to provide access to exits.
5. ☐ Hold open devices and automatic door closures, where provided shall be maintained.
6. ☐ No fire door may be blocked open or otherwise made inoperable.
7. ☐ Stairs serving as required means of egress shall be clear of all obstructions.
8. ☐ Exit light not illuminated; repair or replace.
9. ☐ Exit light not visible from exit approach, provide direction sign to the exit.
10. ☐ Exits and exit stairways are to be illuminated at all times when the building is occupied.
11. ☐ All required exits shall be equipped with approved exit signs in occupancies of 50 or more.
12. ☐ Emergency generators shall be inspected weekly and shall be exercised under load at least every 30 days in accordance with NFPA 110. Provide emergency lighting where required.

C. FIRE PROTECTION SYSTEMS AND APPLIANCES

1. ☐ Provide an approved fire alarm system complying with NFPA 72
2. ☐ The manual fire alarm system is to be tested semiannually and a record of the tests kept on the premises.
3. ☐ Fire alarm system cut-off or inoperative; failure to notify the Fire Prevention Bureau of an inoperative system is a misdemeanor.
4. ☒ Smoke detectors shall be visually inspected at least semiannually and tested in accordance with NFPA 72 E annually.
5. ☐ Smoke detector inoperative; repair or replace.
6. ☐ All smoke detectors other than spot type are to have a sensitivity test every two years.
7. ☐ Central station personnel are to test all sprinkler alarm devices and tamper switches bimonthly.
8. ☐ Atrium smoke removal and control systems shall be tested semiannually.
9. ☐ All horizontal or vertical sliding and rolling fire doors are to be inspected and tested annually.
10. ☐ An approved smoke detector is to be provided within the dwelling unit in an apartment house, condominium, dormitory or duplex and every guest room in a motel and hotel. A detector is also required at the head of a stairway leading to an occupied area and the head of each interior basement stairway.
11. ☐ Records of all required inspections and tests of fire protection systems and devices shall be kept on the premises.
12. ☐ The standpipe system is to be tested at 5 year intervals and a certificate of inspection forwarded to the Fire Prevention Bureau.
13. ☐ The underground and exposed piping for sprinkler systems and hydrants shall be flow tested to determine the interior condition of the piping at least every 5 years.
14. ☐ The fire pump is to be started by a drop in pressure in the system every 7 days and a record is to be kept on the premises of the test.
15. ☐ Provide an automatic fire suppression system in accordance with the International Mechanical Code.
16. ☐ The automatic fire suppression system is to be tested semiannually and a certificate of inspection forwarded to the Fire Prevention Bureau.
17. ☐ Hydrants are to be visually inspected monthly and at least once a year they shall be opened and closed to ensure proper operation and shall be properly lubricated.
18. ☐ Provide all weather roadway access to fire hydrants.
19. ☐ All control valves to standpipe and sprinkler systems are to be visually inspected monthly.
20. ☐ Sprinkler system gauges shall be inspected monthly and are to be tested or replaced every 5 years.
21. ☐ The main drain, waterflow alarm devices, pressure switches, quick-opening devices and tamper switches are to be tested quarterly.
22. ☐ A complete inspection and test of the sprinkler system in accordance with NFPA 25 shall be conducted at least annually by a licensed sprinkler contractor.
23. ☐ The Fire Department connection is to be inspected monthly, if the caps are missing the interior of the connection shall be inspected for obstructions.
24. ☐ The hydraulic name plate is to be inspected quarterly.

D. GENERAL

1. ☐ Extension cords cannot be used as a substitute for fixed wiring; spliced cords are not permitted.
2. ☐ A minimum of 30 inches clearance shall be provided in front of electrical control panels for access.
3. ☐ Provide a street number that can be readily seen from the street.
4. ☐ All openings in a fire rated partition shall be sealed with approved noncombustible material to protect against passage of smoke and fire.
5. ☐ Hazardous accumulation of waste materials or debris must be removed from premises.
6. ☐ Signs stating the maximum occupant load shall be posted in a conspicuous place. Said capacity shall not be exceeded.
7. ☐ Fire drill conducted this date. Exited _____ persons. Drill was _____ Satisfactory _____ Unsatisfactory.
8. ☐ Spraying operation does not comply with the Standard Fire Code.
9. ☐ Storage of flammable and/or combustible liquids are to be stored in safety cans or approved cabinet or room.
10. ☐ Premises and equipment in good order, no visible hazards observed this date.

REMARKS #103320

*Owner Shall have at Least one Fire Extinguisher and two smoke detectors installed in building.

*Owner Should have exit signs mounted with Emergency Lights on them at the point of Egress from the building.

*Due to the circumstances involved at this Location and that it is only temporary I would Like to see that there is A Responsible party here at all times.

The above items are to be corrected as soon as possible; a reinspection will be conducted _____ to verify compliance. Failure to correct the above deficiencies by the compliance date may result in a court summons being issued. Refusal to accept the summons may result in arrest. Any request to provide alternate protection must be filed with the Fire Code Board of Appeals within (15) days.

INSPECTOR	INSPECTION DATE	TIME IN	TIME OUT	1ST REINSP. DATE:	2ND REINSP. DATE:	3RD REINSP. DATE:
458 Brewer	8-11-21	10:00				

COPY RECEIVED BY	POSITION	PHONE NO.	ITEM REFERRED	DATE CORRECTED
[illegible]		901-620-8293		

F-2000.257 Rev.3/27